

TEST SUBMISSION DOCUMENT

14.06.2021

SEISMIC TEST OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Manufacturer Of Test Item/Address

: Ager End. Metal Ürün San. Ve Tic. LTD. ŞTİ.
75. Yıl Mah. Kobi Org. San. Böl. 102. Cad. No:5 Odunpazarı / Eskişehir

Name And Identity Of Test Item

: Server / Data Center Cabinet / AG-SR/DC 42U 8010
800x1000x1950 (mm) Server/Data Center Cabinet.

The Date Of Test

: 27.05.2021

Applied Standards

: • EN IEC 60068-3-3 Environmental testing - Part 3-3: Supporting documentation and guidance - Seismic test methods for equipment
For seismic test within the scope of this standard was carried out with Zone 4 ground acceleration.

• EN 60068-2-6 Environmental testing - Part 2-6: Tests - Test Fc: Vibration (sinusoidal)

• EN 60068-2-57 Environmental testing - Part 2-57: Tests - Test Ff: Vibration - Time-history and sine-beat method

Mounting

: The mounting standard is EN 60068-2-47 Environmental testing Tests. Mounting of specimens for vibration, impact and similar dynamic.

Laboratory Name/Address

: Allianz Teknik accredited by TÜRKAK under registration number AB-1601-T for EN ISO/IEC 17025:2017 as test laboratory.

Türk-Alman Üniversitesi Şahinkaya Cd. No: 90, 34820 Beykoz / İstanbul

Reference No. Of Test Reports/Date

: EQ-AZTEK-21-019/ 14.06.2021

**For further information please see the test report.*

Erkan ÖZDAĞ

Allianz Teknik Manager

Allianz  **Teknik**